



Westwood Shores M.U.D

75 Cottonwood
Trinity, TX 75862

Manhole Inspection Policy

Updated February 21, 2022

Procedures for MUD Manhole Inspections:

Inspections are ongoing at 10 per month and start with Section 1:

- Inspect lids to assure removal
- Inspect lid ring and structure for proper seal
- Check inside coating for cracks, breaks and any infiltration
- Check invert for any debris grease and sand that could cause stoppages
- Provide manhole structure type: concrete, brick or fiberglass
- Mark manholes on sewer collection system map in three colors:
 - Green – no action
 - Yellow- monitor, problem could arise
 - Red – action needed priority
- Record GPS Coordinates
- Report to Board each month
- Turn in checklist Sheet


District Representative

Board Approval:

James Atkinson

James Atkinson, President

Michael McClung

Michael McClung, Vice President

Robert Bluis

Robert Bluis, Secretary

John Wolf

John Wolf, Director

Ken Bateman

Kenneth Bateman, Director